

OLD BRIDGE MUNICIPAL UTILITIES AUTHORITY

RESOLUTION NO. D-26-14

WATER DIVISION

RESOLUTION

WHEREAS, Midtown Water Company has applied to the Old Bridge Municipal Utilities Authority for Preliminary Approval in connection with its Water Application #W14-645 known as The Oaks at Glenwood II located on the west side of Route 9 between Schulmeister Road and Perrine Road, north of the Oaks at Glenwood I proposed development at Block 6303, part of Lot 3.11 and 6 and part of Lot 7 and Block 7000, Lot 1.11 (308 acres); and

WHEREAS, the Applicant proposes to construct approximately 27,500 linear feet of eight (8), inch and ten (10) inch water mains which will connect into the proposed Oaks at Glenwood I and the Middlesex line; and

WHEREAS, the Staff Engineer has reviewed the project and reports submitted, and has recommended Preliminary Approval in accordance with his report dated December 15, 2014; and

NOW, THEREFORE, BE IT RESOLVED by the Commissioners of the Old Bridge Municipal Utilities Authority ("OBMUA") that the Application for Preliminary Approval in connection with Water Application No. W14-645 known as The Oaks at Glenwood II be and the same is hereby granted subject to the following conditions:

- (1) Applicant shall pay all applicable fees
- (2) All comments from this Engineer's Report dated December 15, 2014 shall be addressed with Tentative Water Application.

(3) Applicant shall comply in all respects with the conditions in the report received from the Consulting Engineer, CME Associates, dated December 15, 2014.


(4) The proposed water system of Oaks at Glenwood I (including water mains, pressure reducing valves and the one (1) million gallon on-site water storage tank) that received Tentative Approval on September 19, 2012, shall be constructed and operational prior to the Oaks at Glenwood II connection into that water system.

(5) Water main of Parcel "D" shall be serviced via the twelve (12) inch water main being constructed as part of Oaks at Glenwood I rather than connecting into the existing water transmission main on Water Works Road.

(6) Applicant to fully comply with the Rules and Regulations of the Authority and any Agency having jurisdiction

(7) This Preliminary Water Approval shall expire one (1) year from the date of the resolution

BE IT FURTHER RESOLVED that certified true copies of this resolution be forwarded to Guy Donatelli, Executive Director; Michael Roy, P.E., Staff Engineer; Stephen Florek, Comptroller and The Applicant.



Edward Testino, Secretary

Motion by: Rocco Donatelli
Second by: Edward Testino
Ayes: Donatelli, Greene, Testino, Weber, Haney
Nays: None
Absent: Greenberg
Dated: December 17, 2014
OBMUA0126.RES

OLD BRIDGE MUNICIPAL UTILITIES AUTHORITY

RESOLUTION NO. D-25-14

WATER DIVISION

RESOLUTION

WHEREAS, Woodhaven Village, Inc. has applied to the Old Bridge Municipal Utilities Authority for Minor Approval in connection with its Water Application #W14-433 known as Woodhaven Village, Section 2 Irrigation located on the south side of Texas Road at Woodhaven Boulevard, Block 22001/Lot 1 (0.3 acres); and

WHEREAS, the Applicant proposes to construct one and one half (1½) inch tap and meter pit to service a lawn irrigation system at the entrance of Woodhaven Village, Section 2 which is currently under construction; and

WHEREAS, the Staff Engineer has review the project and reports submitted, has recommended Minor Approval in accordance with his report dated December 12, 2014; and

NOW, THEREFORE, BE IT RESOLVED by the Commissioners of the Old Bridge Municipal Utilities Authority ("OBMUA") that the Application for Minor Approval in connection with Water Application No. W14-433 known as Woodhaven Village, Section 2 Irrigation be and the same is hereby granted subject to the following conditions:

(1) The Applicant shall pay all applicable fees.

(2) Applicant shall comply with and address any and all comments in the Staff Engineer's report dated December 12, 2014.


(3) All proposed water lines to remain privately owned and maintained by the Applicant.

(4) The Applicant shall construct all water improvements in accordance with the Approved Drawings and permits issued by any Agency having jurisdiction.

(5) Applicant shall fully comply with the Rules and Regulations of the Authority and any Agency having jurisdiction.

(6) This Minor Water Approval shall expire one (1) year from the date of the resolution if no construction has taken place within that one (1) year period.

BE IT FURTHER RESOLVED that certified true copies of this resolution be forwarded to Guy Donatelli, Executive Director; Michael Roy, P.E., Staff Engineer; Stephen Florek, Comptroller and The Applicant.



Edward Testino, Secretary

Motion by: Edward Testino
Second by: Richard Greene
Ayes: Donatelli, Greene, Testino, Weber, Haney
Nays: None
Absent: Greenberg
Dated: December 17, 2014
OBMUA0125.RES